

TRANSFORMER VAULT AND COVER

The concrete transformer vault and cover will be specified by our Engineering Department after the transformer size is determined. Equivalent products must have prior approval of our Engineering Department. The top of the vault (not including the cover) is installed at the final grade level so that when the 6" cover is in place, the top of the cover will be 6" above the final grade of the surrounding surface. Knockouts should be made from the inside of the vault. **See Dwg. 243.1 for complete vault installation guidelines.**

Three phase transformer vaults approved for use by customers of the PUD, for transformer installations 1500 kVA and larger, are as follows:

Pacific International Pipe Engineering, Inc.
P.O. Box 9156
Tacoma, WA 98409
(253) 475-8888

57500 Vault with internal grounds
Special Cover
Provide drawing to vendor

Utility Vault Company
P.O. Box 588
Auburn, WA 98002
(253) 839-3500

575-LA Vault with internal grounds
Special Cover
Provide Drawing to vendor

**Consult with our Engineering Department prior to purchasing a vault and cover.
For some installations, a poured-in-place pad will be required
instead of the vault/cover described above.**

**VAULT, TRANSFORMER
3-PHASE PAD-MOUNT (1500 KVA & LARGER)**

DWG. NO.

246.2