



\* Loop enough slack in vault to allow cable to extend 5' above vault cover. Check with PUD for secondary details.

NOTE: To allow for over hang of transformer cooling fins beyond edge of transformer vault cover, the vault cover should be placed 10' from all combustible surfaces, overhangs, windows and doors or 4' from any non-combustible surface having no windows or doors within 10' of vault cover.

\*\* DO NOT DIG within 3' of the PUD's power pole or energized vault.

242\_4.DGN

**FRANKLIN  
PUD**



THE POWER IS YOURS

**THREE-PHASE COMMERCIAL SERVICE  
UNDERGROUND LINE EXTENSION GUIDE**

DWN.  
D. OBERLANDER  
APP.

DATE:  
1-13-97

DWG. NO.

**242.4**